

From: DoNotReply@lewes.gov.uk

Sent: 22 January 2025 15:37:03 (UTC) Coordinated Universal Time

To: lewesplanningcomments

Subject: Comments for Planning Application <LW/24/0820> Customer made comments neither objecting to or supporting the Planning Application

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Comments summary

Dear Sir/Madam,

Planning Application comments have been made. A summary of the comments is provided below.

Comments were submitted at 22/01/2025 3:37 PM from Mr Richard Moon East Sussex Fire & Rescue Service.

Application Summary

Address: Land South Of Green Road Wivelsfield Green East Sussex

Proposal: Outline application for the erection of up to 150 dwellings, with associated works, parking, landscaping, publicly accessible open space, land for education or community use, with access from Green Road and Eastern Road

Case Officer: Mr James Smith

[Click for further information](#)

Customer Details

Name: Mr Richard Moon East Sussex Fire & Rescue Service

Address: Malling House Church Lane Lewes

Comments Details

Commenter Type: Member of the Public

Stance: Customer made comments neither objecting to or supporting the Planning Application

Reasons for comment:

Comments: If this application receives approval the Developer is required to ensure there is sufficient water for firefighting in accordance with the Water UK National Guidance Document. This is usually achieved by the provision of Fire Hydrant(s) attached to a suitable water main. Early

consultation with East Sussex Fire & Rescue Service is recommended to ensure that all needs are met.

Kind regards